



NOTED: THIS DRAWING AND THE INFORMATION ENCLOSED ON IT ARE CONFIDENTIAL AND PROPRIETARY TO CAD TECHNOLOGIES, INC. AND MAY NOT BE REPRODUCED, COPIED, OR DISCLOSED BY ANY PERSON OR ENTITY OUTSIDE OF THE COMPANY IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF A DULY AUTHORIZED EMPLOYEE OF THE COMPANY. COPYRIGHT © 2004

ECH14098

REVISION HISTORY						
ZONE	REV	DESCRIPTION	ECH#	REV'D	CHK'D	DATE



- NOTES:
1. LOCATE POLARITY OF BATTERIES FOR PROPER ORIENTATION DURING INSTALLATION.
  2. FLOOR MOUNTING (ANCHOR) BOLTS ARE NOT FURNISHED.
  3. INSTALLATION ANCHOR BOLT SIZE AND TYPE ARE TO BE DETERMINED BY USER IN ACCORDANCE WITH BUILDING CODES APPLICABLE TO THE ARRANGEMENT DESCRIBED ON THIS DRAWING.
  4. REFERENCE INSTALLATION MANUAL RS01991 FOR: CONNECTOR TORQUE VALUES, MODULE TO MODULE CONNECTIONS & FACEPLATE MOUNTING DETAILS.
  5. CONNECTORS & CABLES ARE SIZED TO THE 15 MIN. RATE TO 1.67 FINAL VPC AT 895.1 AMPS. CONNECTORS RESULT IN <30mV DROP AND CABLES RESULT IN <100mV DROP.

<small>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES AND DECIMALS THEREOF</small> X .125" XXX THIRD ANGLE PROJECTION NATIONAL STANDARD SEE BOM ABOVE PER: SPEC:		DRAWN: Y. HODGES/ CHECKED: [Signature] DATE: 1/28/15 APPROVED: [Signature] DATE: 2/2/15	ALL SHEETS ARE THE SAME REVISION STATUS <b>CAD TECHNOLOGIES, INC.</b> 1400 UNION MEETING, BLUE BELL, PA 19422-0588 www.cadtechno.com TITLE: CONNECTION DIAGRAM 480V 6X8 AT-15P SIZE: D CAGE CODE: [Blank] DRAWING NUMBER: E1568240CE01 REVISION: 0 SCALE: NTS SHEET 1 OF 2
--	--	---	---

