



NOTICE: THIS PRINT AND THE INFORMATION SHOWN THEREON IS THE PROPERTY OF C&D TECHNOLOGIES, INC. AND IS BEING FURNISHED AS A CONFIDENTIAL DISCLOSURE. IT MAY NOT BE DELIVERED TO OTHERS NOR REPRODUCED FOR THE GENERAL CIRCULATION WITHOUT THE WRITTEN APPROVAL OF C&D TECHNOLOGIES, INC.

REVISION HISTORY							
ZONE	REV	DESCRIPTION	ECN#	REV'D	CHK'D	DATE	APPROVED



POST TERMINAL DETAIL
(0.25" [6.4mm] THICK)

NOTES :

1. ALL DIMENSIONS ARE REFERENCE.
2. ITEMS 2, 3 & 4 ARE SUPPLIED IN ACCESSORY KIT, RE02537.
3. RACK AND SPILL CONTAINMENT ARE ADDITIONAL. THEY MUST BE ORDERED AS SEPARATE ITEMS.
4. C&D SEISMIC RACKS REQUIRE BATTERY SPACERS, PART NO. RE01640, QUANTITY 19.
5. REGARDING SPILL CONTAINMENT, PART NUMBER REFLECTS OUTSIDE DIMENSIONS OF SPILL CONTAINMENT BARRIERS, INSIDE DIMENSIONS ARE -2".

120 VDC BATTERY SYSTEM			
ITEM	QTY.	PART NO.	DESCRIPTION
1A	20	CW06645	3DCU-3 BATTERY UNIT (J08980)
1B	20	CW06480	3DCU-5 BATTERY UNIT (J08980)
2	19	RA02176-10.5	INTER-UNIT CONNECTOR #4 CABLE 10.5" LONG
3	40	PB00253	BOLT ASS'Y, LEAD/BRASS (1) PB00252 CAST TERMINAL NUT 1/4X20 (1) PB00250 CAST SMALL POWER BOLT
4	60	PV00483	FLAME ARRESTOR ASSY "D"
* ADDITIONAL ITEMS			
5A	1	RDB0700-10P	RACK ASSEMBLY, 1-TIER (M11460)
5B	1	RDB0700-10EP1P	RACK ASSEMBLY, 1-TIER EP1 (M11461)
5C	1	RDB0700-10EP2P	RACK ASSEMBLY, 1-TIER EP2 (M11462)
6	1	SP20124L	SPILL CONTAINMENT

* ADDITIONAL ITEMS MUST BE ORDERED SEPARATELY

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES ± TOLERANCES ON: DECIMALS ANGLES		DRAWN G.R.KUKEL	DATE 4/10/07	C&D TECHNOLOGIES, INC. 1400 UNION MEETING ROAD, BLUE BELL, PA 19422-0858 www.cdtechno.com
X	XX	XXX	CHECKED <i>[Signature]</i> 12/14/09	
THIRD ANGLE PROJECTION		APPROVED <i>[Signature]</i> 1/19/09	APPROVED	TITLE BATTERY ARRANGEMENT - 120 VDC 1-TIER RACK, (20) 3DCU-3 & 5
MATERIAL		FILE: RE02537-1T	SCALE	SIZE CAGE CODE C DRAWING NUMBER RE02537-1T REVISION 0
SHEET 1 OF 1			12/2000	